

**FOURTEEN BASIC
ENERGY CONSERVATION
MEASURES
TO
REDUCE ENERGY COSTS**



**By: Henry Manczyk, CPE, CEM
Director of Facilities Management
Monroe County, New York**

Fourteen Basic Energy Conservation Measures

Introduction	2
References	3
Definitions and equations.....	4
1. Window replacement.....	8
2. Blown-in ceiling insulation	11
3. Adding exterior wall insulation.....	13
4. Replace roof insulation.....	15
5. Insulation blanket for domestic hot water heater	17
6. Replace overhead door	19
7. Outdoor air temperature lockout for boiler	21
8. Thermo Flue vent damper for domestic hot water heater	23
9. Repair condensate leak.....	25
10. Insulate pipes.....	26
11. Control running time of lavatory exhaust fans.....	28
12. Caulk exterior windows	29
13. Lower domestic hot water supply temperature	30
14. Install thermostatic control valves on radiators and convectors	31

Fourteen Basic Energy Conservation Measures

Introduction

**By Henry Manczyk, CPE, CEM
Director of Facilities Management
Monroe County, New York**

Energy Conservation is important for several reasons: Economic, Environmental and Social. Economically, it makes sense since energy is a commodity which we cannot afford to waste. Environmentally, it's makes sense as well. It has been universally recognized that the more efficiently we utilize energy, much less carbon dioxide will be released into the atmosphere, thus preserving our environment and avoiding as much as possible the unpredictable changes in our climate. The other benefit that results in the overall objectives of energy conservation is the social factor which creates a significant amount of jobs in the manufacturing and installation of energy efficient equipment.

An effective building energy management system is essential to ensure that energy savings are realized while providing a work environment that maximizes the comfort and performance of the building's occupants.

A successful energy management program requires full commitment by the owners and building occupants as well as by a professional energy manager with a holistic view of energy management who can capture the savings the program has produced.

Well-planned energy management programs systematically set energy use goals and explore ways to achieve them, such as an installation of energy efficient equipment and a revised standard of operation and maintenance procedures.

In any effective energy management conservation program, the first step is to perform an energy audit of the facility. A thorough evaluation will establish the load profile, identify all energy consuming systems as well as evaluate the condition of the systems, and analyze the impact of improvements to those systems.

The energy audit and survey will generate a report that clearly identifies and defines potential energy conservation opportunities. The report should recommend strategies and equipment modification based on economic analysis to reduce building energy consumption.

Normally, most of the recommended energy conservation measures can be achieved with little or no cost. Others, however, require investment to get implemented if the project is to be cost effective.

This article identifies 14 case studies of energy conservation measures. Each example presents its desired values and return on investment.

References:

- “Energy Management of Commercial Buildings”, By: “Caddet”, Coded Analysis Series 19, May 1996
<http://www.aceee.org/pubs/cad19.htm>
- “Good Energy Management Begins with an Energy Audit”, By: “Energy User News” Posted on July 10, 2000 on the internet.
http://www.energyusernews.com/eun/cda/article_information/fundamentals_item/0,2637,642,1,00.html
- “Why We Should Conserve Energy” By: The Association for the Conservation of Energy 2000 (ACE)
www.ukace.org/encons.htm

Issued: August 13, 2002

Definitions and Equations

- (1) Equation for heat loss from a building

$$Q = \text{H.L.M.} \times \Delta T$$

Where

$$Q = \text{Btu/Hr}$$

$$\text{H.L.M.} = \text{Heat loss multiplier} = \text{U-factor} \times \text{Area} = \frac{\text{BTU}}{\text{Hr} \cdot ^\circ\text{F}}$$

ΔT = Temperature difference

= Indoor temperature – outdoor temperature

- (2) Equation for total heat loss for a heating season using the Bin Hour method.

$$Q = \text{H.L.M.} \times \Delta T \times \text{Hour}$$

Where

$$Q = \text{Btu}$$

$$\text{H.L.M.} = \text{Heat loss multiplier} = \text{U-factor} \times \text{Area} = \text{BTU/Hr} \cdot ^\circ\text{F}$$

ΔT = Temperature difference

= Indoor temperature – outdoor temperature

Hour = Bin Hour

NOTE: The bin hours are the length of time that the outside air temperature is between a given temperature range. The Bin temperature used in these calculations are the mid-point of the given temperature range.

The total heat loss for a season with a constant indoor temperature of 70 °F is:

$$Q = H.L.M. \times (T_2 - T_1) \times \text{Hours}$$

This can be written mathematically:

$$\text{Total Heat Loss} = H.L.M. \times \sum \Delta T \text{ (Bin Hours)}$$

Where,

$\sum \Delta T$ (Bin Hour) is the summation of each ΔT times the corresponding bin hours for the heating season.

At 70 °F the $\sum \Delta T$ (Bin Hour) is:

(70 - 57) x	364 Hour	=	4,732 °F-Hr
(70 - 52) x	439	=	7,902
(70 - 47) x	503	=	11,569
(70 - 42) x	566	=	15,848
(70 - 37) x	745	=	24,585
(70 - 32) x	928	=	35,264
(70 - 27) x	625	=	26,875
(70 - 22) x	402	=	19,296
(70 - 17) x	247	=	13,091
(70 - 12) x	172	=	9,976
(70 - 7) x	72	=	4,536
(70 - 2) x	23	=	1,564
			175,238 °F-Hr

Note: The above bin hours were derived from Niagara Falls, N.Y. climatological data.

Niagara Falls, N.Y. Region
Total Bin Hours in the Range of 0°F - 59°F

RANGE	MID-POINT	SHIFTS			TOTAL HOURS
		00:30 - 08:30	08:30 - 16:30	16:30 - 00:30	
59-55	57°F	96	143	125	364
54-50	52°F	137	143	159	439
49-45	47°F	167	157	179	503
44-60	42°F	197	181	188	566
39-35	37°F	254	238	253	745
34-30	32°F	345	276	307	928
29-25	27°F	227	185	213	625
24-20	22°F	152	117	133	402
19-15	17°F	106	60	81	247
14-10	12°F	74	39	59	172
9-5	7°F	39	13	20	72
4-0	2°F	12	5	6	23
Total Hours in the Range of 0°F - 59°F					5,086

NOTE! It is assumed that, with the building improvements, energy is not consumed at an outside air temperature of 60°F or above.

TOTAL AVAILABLE HOURS DURING HEATING SEASON
FROM
SEPTEMBER 1 TO MAY 1

<u>MONTH</u>	<u>DAYS</u>	<u>HOURS</u>
September	30	720
October	31	744
November	30	720
December	31	744
January	31	744
February	28	672
March	31	744
April	30	<u>720</u>
TOTAL AVAILABLE HOURS =		5,808

1) Equation: Heat Saved

$$Q = A \times \Delta U \times W \times 10^{-6}$$

Where

$$Q = \text{Energy Saved} = \text{MMBtu's}$$

$$A = \text{Area of Glass} = 1,062 \text{ Ft}^2$$

$$\Delta U = \text{Change in U-Factor} = (1.1 - .5) = .6$$

$$W = \text{Weather Multiplier} = 75^\circ \longrightarrow 200,711 \text{ Hr-}^\circ\text{F}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$Q = (1,062)(.6)(200,711)(10^{-6}) = 127.9 \text{ MMBtu's}$$

2) Equation: Infiltration Savings

$$Q = L \times \Delta C \times F \times S \times 1.08 \times W \times 10^{-6}$$

Where

$$Q = \text{Energy saved} = \text{MMBtu's}$$

$$L = \text{Length of crack on wall with most windows} = 420 \text{ Ft}$$

$$\Delta C = \text{Change in crack} = (.001-.001) = .004 \text{ Ft}$$

$$F = \text{Wind correction factor} = .43$$

$$S = \text{Speed of wind} = 440 \text{ Fpm}$$

$$1.08 = \text{Conversion Factor}$$

$$W = \text{Weather Multiplier} = 75^\circ\text{F} \longrightarrow 200,711 \text{ Hr-}^\circ\text{F}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$Q = (420)(.004)(.43)(440)(1.08)(200,711)(10^{-6})$$

$$= \underline{68.9 \text{ MMBtu's}}$$

ENERGY CONSERVATION MEASURE #1 (CONT)

WINDOW REPLACEMENT

Total Energy Savings

Heat: 127.9 MMBtu's
Infiltration: 68.9 MMBtu's
196.8 MMBtu's

Cost: 196.8 MMBtu's x \$6.37/MMBtu = \$1,253.62

Equipment Cost: Cost supplied by a window installer includes labor


Office Window System = \$6,000

Garage Fixed Window = \$6,000 (See Note)
\$12,000

Note: The fixed windows are the windows that are in the garage area and not the same as the window system for the office area. These fixed windows would have a fixed interior second pane of glass.

Simple Payback

Equipment Cost \$12,000 = 9.6 years
Savings 1,253.62



- ① EXISTING FIXED WINDOW
- ② OPERABLE PART OF EXISTING WINDOW WHICH OPENS OUTWARD
- ③ NEW SLIDING WINDOW FOR EASY ACCESS TO EXISTING OPERABLE WINDOW
- ④ AIR BREAK TO STOP AIR MOVEMENT INTO THE SPACE BETWEEN THE FIXED WINDOWS
- ⑤ NEW INTERIOR FIXED WINDOW

ENERGY CONSERVATION MEASURE #2

BLOWN-IN CEILING INSULATION

Equation:

$$Q = A \times \Delta U \times W \times 10^{-6} \times C$$

Where

$$Q = \text{Energy Saved} = \$$$

$$A = \text{Area} = 2520 \text{ Ft}^2$$

$$\Delta U = \text{Change in U-Factor} = (.171 - .042) = .129$$

$$W = \text{Weather Multiplier} = 175,276 \text{ }^\circ\text{F} - \text{Hr}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of Gas} = \$6.37$$

$$Q = (2520)(.129)(175,276)(10^{-6})(6.37) = \$363$$

Equipment Cost


\$1,320

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$1,320}{\$363} = \underline{\underline{3.6 \text{ years}}}$$

ENERGY CONSERVATION
MEASURE #2

ADDING ADDITIONAL
INSULATION IN THE CEILING



ITEM	PRESENT	PROPOSED
① OUTSIDE AIR FILM	.17	.17
② BUILT- ROOFING	.33	.33
③ 3" CONCRETE	3.33	3.33
④ AIR SPACE	.93	
⑤ INSULATION		19.00
⑥ TILE	.47	.47
⑦ INSIDE AIR FILM	.61	.61
	<hr style="width: 50%; margin-left: auto; margin-right: 0;"/> 5.84	<hr style="width: 50%; margin-left: auto; margin-right: 0;"/> 23.91
U-FACTOR= $1/R_{\Sigma}$.171	.042

ENERGY CONSERVATION MEASURE #3

ADDING INSULATION TO EXTERIOR WALL OF A HOUSE

Equation:

$$Q = A \times \Delta U \times W \times 10^{-6}$$

Where

$$Q = \text{Energy saved} = \text{MMBtu's}$$

$$A = \text{Area of wall} = 520 \text{ Ft}^2$$

$$\Delta U = \text{Change in U-factors} = (.322 - .107) = .215$$

$$W = \text{Weather multiplier} = 70^\circ \longrightarrow 175,276 \text{ Hr-}^\circ\text{F}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$Q = (520 \text{ Ft}^2)(.215)(175,276)(10^{-6}) = 19.6 \text{ MMBtu's}$$

Cost

$$19.6 \text{ MMBtu} \times \frac{\$6.37}{\text{MMBtu}} = \$125/\text{year}$$

Equipment cost: 1985 "Means: Construction Cost Data"

$$\text{Urethane 1" R-5.8} \quad 520 \text{ Ft}^2 \times \$.72/\text{Ft}^2 = \$374$$

$$\text{Gypsum wallboard 12" } \quad 520 \text{ Ft}^2 \times \$.75/\text{Ft}^2 = \$390$$

$$\text{Furring attach to masonry} \quad 60 \times 8 \text{ Ft} \times .57/\text{Ft} = \underline{\$274}$$


\$1,038

Simple Payback

$$\frac{\text{Equipment Cost} = \$1,038}{\text{Saving} \quad \$125} = \underline{8.3 \text{ years}}$$

ENERGY CONSERVATION
MEASURE #3

ADDING ADDITIONAL INSULATION
TO THE INTERIOR OF A HOUSE



ITEM	R-VALUES	
	EXISTING	PROPOSED
① OUTSIDE AIR FILM	.17	.17
② 4" FACE BRICK	.44	.44
③ 1/2" MORTAR	.10	.10
④ 8" BLOCK	1.72	1.72
⑤ RIDGE INSULATION		5.8
⑥ 1"x3" VERTICAL FURRING		
⑦ 1/2" GYPSUM WALLBOARD		.45
⑧ INSIDE AIR SPACE	.68	.68
	<u>3.11</u>	<u>9.36</u>

Existing: U-FACTOR = $1/R = 1/3.11 = .322$
BTU/HR-FT²-F

Proposed: U-FACTOR = $1/R = 1/9.36 = .107$ BTU/HR-FT²-F

ENERGY CONSERVATION MEASURE #4

REPLACE ROOF INSULATION

Equation: $Q = A \times \Delta U \times W \times 10^{-6} \times C$

Where

$$Q = \text{Energy saved} = \$$$

$$A = \text{Area of roof with rigid insulation} = 6,495$$

ΔU = Change in U-factors

$$\text{Case 1} = (.051 - .046) = .005$$

$$\text{Case 2} = (.051 - .040) = .011$$

$$\text{Case 3} = (.051 - .033) = .018$$

$$W = \text{Weather multiplier with night setback} = 139,996 \text{ H-}^\circ\text{F}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of Gas} = \$6.37/\text{MMBtu}$$

$$\text{Case 1: } (6,495)(.005)(139,996)(10^{-6})(6.37) = \$29$$

$$\text{Case 2: } (6,495)(.011)(139,996)(10^{-6})(6.37) = \$64$$

$$\text{Case 3: } (6,495)(.018)(139,996)(10^{-6})(6.37) = \$104$$

Equipment Cost

$$\text{Case 1} = 6,495 \text{ Ft}^2 \times \$0.67/\text{Ft}^2 = \$4,352$$

$$\text{Case 2} = 6,495 \text{ Ft}^2 \times \$0.78/\text{Ft}^2 = \$5,066$$

$$\text{Case 3} = 6,495 \text{ Ft}^2 \times \$0.92/\text{Ft}^2 = \$5,975$$

Simple Payback


$$\text{Case 1: } \frac{\text{Equipment Cost}}{\text{Saving}} = \frac{\$4,352}{29} = 150 \text{ years}$$

$$\text{Case 2: } = \frac{\$5,066}{64} = 79 \text{ years}$$

$$\text{Case 3: } = \frac{\$5,975}{104} = 57 \text{ years}$$

ENERGY CONSERVATION
MEASURE #4

REPLACEMENT OF ROOF INSULATION



ITEM	EXISTING	1	CASES 2	3
① OUTSIDE AIR FILM	.17			
② BUILT-UP ROOFING	.33			
③ INSULATION	14.58	16.67	20.00	25.00
④ 2" CONCRETE	3.33			
⑤ TILE	.47			
⑥ INSIDE AIR FILM	.61			
	R = $\frac{19.49}{}$	$\frac{21.58}{}$	$\frac{24.91}{}$	$\frac{29.91}{}$
U-FACTOR = $\frac{1}{R}$.051	.046	.040	.033

ENERGY CONSERVATION MEASURE #5

INSULATION BLANKET FOR DOMESTIC HOT WATER HEATER

Formula

$$Q = Sa \times (1/R_1 - 1/R_2) \times \Delta T \times D \times 10^{-6} \times C$$

Where

$$Q = \text{Energy Saved} = \$$$

$$Sa = \text{Surface area of tank} = 33.3 \text{ FT}^2$$

$$R_1 = \left[\frac{.917LN\left(\frac{11}{10}\right)}{.03} + .61 \right] = 3.52$$

$$R_2 = \left[\frac{1.125LN\left(\frac{13.5}{10}\right)}{.03} + \frac{1.125LN\left(\frac{13.5}{11}\right)}{.03} + .61 \right] = 19.56$$

$$\Delta T = \text{Temperature difference} = (120 - 60) = 60^\circ \text{F}$$

$$D = \text{Length of Year} = 8760 \text{ Hr.}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of Gas} = \$6.37$$

$$Q = (33.3)(1/3.52 - 1/19.56)(10^{-6})(60)(8760)(6.37) = \$32$$



Equipment Cost: \$55

Simple payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$55}{32} = \underline{1.72 \text{ years}}$$

ENERGY CONSERVATION MEASURE #5

INSULATED BLANKET FOR A DOMESTIC HOT WATER HEATER



RESISTANCE FOR A CYLINDER

$$\text{PRESENT} = \left[\frac{R2 \text{ LN} \left(\frac{R2}{R1} \right) + H}{K1} \right]$$

$$\text{PROPOSED} = \left[\frac{R3 \text{ LN} \left(\frac{R2}{R1} \right)}{K1} + \frac{R3 \text{ LN} \left(\frac{R3}{R2} \right)}{K2} + H \right]$$

ENERGY CONSERVATION MEASURE #6

REPLACE OVERHEAD DOORS

Equation: Heat Saved

$$Q = A \times \Delta U \times W \times 10^{-6} \times C$$

Where

$$Q = \text{Energy saved} = \$$$

$$A = \text{Area of Doors} = 984 \text{ Ft}^2$$

$$\Delta U = \text{Change in U-Factor} = (.721 - .077) = .644$$

$$W = \text{Weather multiplier} = 140,314 \text{ }^\circ\text{F-Hr}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of Gas} = \$6.37$$

$$Q = (984)(.644)(140,314)(10^{-6})(6.37) = \$566$$

Equation: Infiltration

$$Q = P \times \Delta S \times 204.34 \times W \times 10^{-6} \times C$$

Where

$$Q = \text{Energy Saved} = \$$$

$$P = \text{Perimeter of Doors} = 332 \text{ Ft.}$$

$$\Delta S = \text{Change in crack} = (.01 - .001) = .009$$

$$204.34 = \text{Conversion factor} = (440 \times .43 \times 1.08 = 204.34)$$

$$W = \text{Weather multiplier} = 140,314 \text{ }^\circ\text{F-Hr}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of Gas} = \$6.37$$

$$Q = (332)(.009)(204.34)(140,314)(10^{-6})(6.37) = \$546$$


Equipment Cost: \$11,958

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$11,958}{546+566} = \underline{10.8 \text{ Years}}$$

ENERGY CONSERVATION
MEASURE #6

NEW OVERHEAD
DOORS



ENERGY CONSERVATION MEASURE #7

OUTDOOR AIR TEMPERATURE LOCKOUT FOR BOILER

Formula: Heat Saved

$$Q = \text{H.L.M.} \times \Delta T \times H \times 10^{-6} \times C$$

Where

$$Q = \text{Energy saved} = \$$$

$$\text{H.L.M.} = \text{Heat loss multiplier} = 4,534 \text{ Btu/Hr-}^\circ\text{F}$$

$$\Delta T = \text{Temperature change} = 68 - 62 = 6^\circ\text{F}$$

$$H = \text{Hours}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of oil} = \$6.83$$

$$Q = (4,534)(6)(284)(10^{-6})(6.83) = \$53$$

Formula: Electric Saved

$$Q = \text{Hp} \times .746 \times H \times C$$

Where

$$Q = \text{Electric saved} = \$$$

$$\text{Hp} = \text{Horsepower} = .25$$

$$.746 = \text{Conversion factor}$$

$$H = \text{Hours} = 2,869$$

$$C = \text{Cost of electric} = \$.07$$

$$Q = (.25)(.746)(2,869)(.07) = \$37$$


Equipment Cost: \$240

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$240}{37+53} = 2.66 \text{ years}$$

ENERGY CONSERVATION
MEASURE #7

BOILER OUTDOOR
LOCKOUT CONTROLLER



Equation:

$$Q = 1,872 \times A \times R \times (1/T_2) \times (dT_a/T_1) \times dT_a \times M \times D \times 10^{-6} \times C$$

Where

$$Q = \text{Energy saved} = \$$$

$$1,872 = \text{Conversion Factor} = ((104,000/60) \times 1.08 = 1,872)$$

$$A = \text{Area of vent} = \pi(4)^2/4 = 12.6 \text{ in}^2$$

$$R = \text{Resistance factor} = 2.236$$

$$T_2 = \text{Average absolute gas vent temperature} = 575^\circ\text{R}$$

$$dT_a = \text{Average difference in gas and outside air}$$

$$= 115 - 34 = 81^\circ\text{F}$$

$$T_1 = \text{Absolute outside air temperature} = 494^\circ\text{R}$$

$$M = \text{Time heater is on standby} = 22 \text{ hours}$$

$$D = \text{Length of heating season} = 212 \text{ days}$$

$$10^{-6} = \text{MMBtu/Btu}$$


$$C = \text{Cost of gas} = \$6.37$$

$$Q = (1,872)(12.6)(2.236)(1/575)(81/494)^5(81)(22)(212)(10^{-6})(6.37) \\ = \$89$$

Equipment Cost: \$50

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$50}{89} = 0.6 \text{ years}$$



ENERGY CONSERVATION MEASURE #9

REPAIR CONDENSATE LEAK

Equation:

$$Q = M \times 8.33 \times C \times \Delta T \times L \times 10^{-6} \times 6.37$$

Where

Q = Energy saved = \$

M = Make-up water = 100 gallons/day

8.33 = Conversion factor

C = Specific heat = 1 Btu/Lb - °F

ΔT = Change in temperature = 190-50 = 140°F

L = Length of season = 212 days

10^{-6} = MMBtu/Btu

C = Cost of Gas = \$6.37

$$Q = (100)(8.33)(1)(140)(212)(10^{-6})(6.37) = \$157$$

Equipment: \$1,200

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$1,200}{157} = \underline{7.6 \text{ years}}$$

ENERGY CONSERVATION MEASURE #10

INSULATE PIPES

Equation

$$Q = Sa \times (1/R_1 - 1/R_2) \times \Delta T \times L \times 10^{-6} \times C$$

Where

$$Q = \text{Energy saved} = \$$$

$$Sa = \text{Surface area of pipes}$$

$$= 150 \text{ Ft.} \times (\pi(1.5/12)) = 58.9 \text{ Ft}^2$$

$$\left[R_1 = \frac{0.063 \text{Ln}\left(\frac{.755}{.75}\right)}{25} + .61 \right] = .61002$$

$$\left[R_2 = \frac{.146 \text{Ln}\left(\frac{1.755}{.75}\right)}{.03} + \frac{.146 \text{Ln}\left(\frac{1.755}{.755}\right)}{25} + .61 \right] = 4.75$$

$$\Delta T = \text{Change in temperature} = 140 - 60^\circ\text{F} = 80^\circ\text{F}$$

$$L = \text{Length of heating season} = 5,808 \text{ Hours}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of Gas} = 6.37$$


$$Q = (58.9)(1/.61002 - 1/4.75)(80)(5,808)(10^{-6})(6.37) \\ = 249$$

Equipment Cost: Means "CONSTRUCTION COST" includes labor

$$150 \text{ Ft} \times \$3.14 = \$471$$

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Saving}} = \frac{\$471}{249} = \underline{\underline{1.9 \text{ years}}}$$



R3: RADIUS TO EXTERIOR OF INSULATION
R2: RADIUS TO EXTERIOR OF PIPE
R1: RADIUS TO INTERIOR OF PIPE

BARE PIPE

$$\text{RESISTANCE} = \left[\frac{R2 \text{ LN} \left(\frac{R2}{R1} \right)}{K1} + H \right]$$

INSULATED PIPES

$$\text{RESISTANCE} = \left[\frac{R3 \text{ LN} \left(\frac{R2}{R1} \right)}{K1} + \frac{R3 \text{ LN} \left(\frac{R3}{R2} \right)}{K2} + H \right]$$

ENERGY CONSERVATION MEASURE #11

CONTROL RUNNING TIME OF LAVATORY EXHAUST FANS

Equation

$$Q = \text{CFM} \times 1.08 \times T \times W \times 10^{-6} \times C$$

Where

Q = Energy Saved

CFM = Exhaust air = 200 CFM

1.08 = Conversion Factor

T = % Exhaust is off = 71% or .71

W = Weather multiplier = 149,841 H-°F

10^{-6} = MMBtu/Btu

C = Cost of Gas = \$6.37

$$Q = (200)(1.08)(.71)(149,841)(10^{-6})(6.37) = \$146$$

Equipment Cost:

\$70

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$70}{146} = \underline{\underline{0.48 \text{ years}}}$$

ENERGY CONSERVATION MEASURE #11

CAULK EXTERIOR WINDOWS

Equation

$$Q = P \times \Delta H \times 59.2 \times W \times 10^{-6} \times C$$

Where

$$Q = \text{Energy saved} = \$$$

$$P = \text{Perimeter of windows} = 1,030 \text{ Ft.}$$

$$\Delta H = \text{Change in crack} = (.01 - .001) = .009$$

$$59.2 = \text{Conversion factor} = (220 \times .25 \times 1.08 = 59.4)$$

$$W = \text{Weather multiplier} = 175,276 \text{ Hr-}^\circ\text{F}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of Gas} = \$6.37$$

$$\begin{aligned} Q &= (1,030)(.009)(59.2)(175,276)(10^{-6})(6.37) \\ &= \$613 \end{aligned}$$

Equipment Cost with Labor:

$$\$409$$

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$409}{613} = \underline{0.67 \text{ years}}$$

ENERGY CONSERVATION MEASURE #13

LOWER DOMESTIC HOT WATER SUPPLY TEMPERATURE

Equation

$$Q = N \times M \times L \times G \times \Delta T \times S \times 10^{-6} \times C$$

Where

Q = Energy saved = \$

N = Number of showers = 120 showers/day

M = Minute per shower = 5 min./shower

L = Length of school season = 180 days

G = Flow rate = 16.7 Lb/Min.

ΔT = Temperature saved = 160-120 = 40°F

S = Specific heat of water = 1 Btu/Lb-°F

10^{-6} = MMBtu/Btu

C = Cost of Gas = 6.37

$$Q = (120)(5)(180)(16.7)(40)(1)(10^{-6})(6.37)$$
$$= \underline{\underline{\$459}}$$

ENERGY CONSERVATION MEASURE #14

NON-ELECTRIC CONTROL VALVES FOR RADIATORS AND CONVECTORS

Equation $Q = \text{H.L.M.} \times \Delta T \times H \times 10^{-6} \times C$

Where

$$Q = \text{Energy saved} = \$$$

$$\text{H.L.M.} = \text{Heat Loss Multiplier} = 2,300 \text{ Btu/Hr-}^\circ\text{F}$$

$$\Delta T = \text{Temperature saved} = 4^\circ\text{F}$$

$$H = \text{Hour of season} = 5,808 \text{ Hr.}$$

$$10^{-6} = \text{MMBtu/Btu}$$

$$C = \text{Cost of Gas} = \$6.37$$

$$Q = (2,300)(4)(5,808)(10^{-6})(6.37) = \$340$$

Equipment Cost: \$500

Simple Payback

$$\frac{\text{Equipment Cost}}{\text{Savings}} = \frac{\$500}{340} = 1.5 \text{ years}$$

ENERGY CONSERVATION MEASURE #14

NON-ELECTRIC CONTROL VALVES FOR RADIATORS AND CONVECTORS

